

2012 International Plumbing Code

Note: An asterisk at the beginning of a section identifies a new amendment with the 2012 code edition.

- "E. The International Plumbing Code adopted by reference in Section 101.4.3, 2012 International Building Code is hereby amended as follows:
- 1 Section 102.8 (Referenced codes and standards) is amended by adding the following exception:

'Exception: Any reference to the ICC Electrical Code shall mean the National Electrical Code, as adopted and amended by the City of College Station.'
 - 2 Section 106.3 (Application for permit) is amended by deleting the text in said section and replacing it with the following:

'The code official may require a permit application for work regulated by this code.'
 - 3 Section 106.6.2 (Fee Schedule) is amended by deleting this section in its entirety.
 - 4 Section 106.6.3 (Fee refunds) is amended by deleting the text in said section and replacing it with the following:

'The City Manager or designee is authorized to establish a refund policy.'
 - 5 Section 108.5 (Stop work orders) is amended by inserting the following amounts in the blanks provided at the end of said section:

'twenty-five (\$25.00) in the first blank and two-thousand (\$2,000.00) in the second blank'
 - 6 Section 109 (Means of Appeal) is amended by deleting the section in its entirety.
 - 7 Section 305.4.1 (Sewer depth) is amended by inserting "twelve (12)" in both blanks and adding the following sentence to the end of said section.

'Where conditions prohibit the required amount of cover, cast iron pipe with approved joints may be used unless other means of protecting the pipe is provided as approved by the Building Official.'
 - 8 Section 312.1 (Required tests) is amended by deleting the following text from said section:

' , for piping systems other than plastic, by'
 - 9 Section 312.2 (Drainage and vent water test) is amended by deleting said section in its entirety and replacing with the following:

'312.2 Drainage water test. A water test shall be applied to the drainage system either in its entirety or in sections. If applied to the entire system, all openings in the piping shall be tightly closed, except the highest opening, and the system

shall be filled with water to the point of overflow. If the system is tested in sections, each opening shall be tightly plugged except the highest opening of the section under test, and each section shall be tested with not less than a 10-foot head of water. This pressure shall be held for at least 15 minutes. The drainage system shall then be tight at all points.'

- 10 Section 312.3 (Drainage and vent air test) is amended by deleting said section in its entirety and replacing with the following:

'312.3 Drainage air test. An air test shall be applied to the drainage piping by forcing air into the system until there is uniform gauge pressure of 5 pounds per square inch (psi) or sufficient to balance a 10-inch column of mercury. This pressure shall be held for a test period of at least 15 minutes. Any adjustment to the test pressure required because of changes in ambient temperature or the seating of gaskets shall be made prior to the beginning of the test period.'

- 11 Section 312.10 (Inspection and testing of backflow prevention assemblies.) is amended by deleting said section in its entirety and replacing with the following:

'312.10 Inspection and testing of backflow prevention assemblies. Upon initial installation, an inspection shall be made of all backflow prevention devices and assemblies to determine whether they are operable. Testing of all backflow prevention devices and assemblies shall be in accordance with Chapter 11, Section 10, Subsection F, of the Code of Ordinances, City of College Station, Texas.'

- 12 Section 410.3 (Substitution) is amended by deleting the last sentence in said section and replacing it with the following:

'Where bottle water dispensers are provided in other occupancies, drinking fountains shall not be required.'

- 13 Table 605.3 (Water Service Pipe) is amended by deleting the following materials:

Acrylonitrile butadiene styrene (ABS) plastic pipe
Asbestos – cement pipe
Polybutylene (PB) plastic pipe and tubing
Polyethylene (PE) plastic pipe
Polyethylene (PE) plastic tubing
Polyethylene/aluminum/polyethylene (PE-AL-PE) pipe

- 14 Section 606 (Installation of the Building Water Distribution System) is amended by adding section 606.8 to read as follows:

'606.8 Materials below slab. Water distribution piping installed under concrete slabs shall be copper (minimum type K), cross-link polyethylene (PEX) tubing, or cross-linked polyethylene/aluminum/ polyethylene (PEX-AL-PEX) pipe, all installed without joints or connections. Materials subject to corrosion shall be protected when exposed to concrete or corrosive soils.'

- 15 Section 606 (Installation of the Building Water Distribution System) is amended by adding section 606.9 to read as follows:

'606.9 Sleeved cross-polyethylene piping or tubing. 'When a sleeve is provided for cross-linked polyethylene (PEX) plastic piping or tubing installed under concrete slabs the annular space between the piping or tubing and the sleeve

must be caulked, foamed, or otherwise sealed to prevent the entrance of termiticide.'

- 16 Section 608.16.5 (Connections to lawn irrigation systems) is amended by deleting the first sentence in said section and replacing it with the following:

'The potable water supply to lawn irrigation systems shall be protected against backflow by an atmospheric vacuum breaker, a pressure vacuum breaker assembly, a reduced pressure principle backflow prevention assembly or a double check.'

- 17 Section 701.2 (Sewer required) is amended by deleting the section in its entirety and replacing with the following:

'701.2 Sewer required. Every building in which plumbing fixtures are installed and all premises having sanitary drainage piping shall be connected to an approved sewer. Private sewage systems must comply with City of College Station's Code of Ordinances (Chapter 11, Section 2). All private sewage disposal systems must comply with the latest adopted standards of the Texas Commission on Environmental Quality and be installed under the direction of the Brazos County Health Department. The installer shall be licensed by the Texas Commission on Environmental Quality.'

- 18 Section 1003.3.4 (Hydromechanical grease interceptors and automatic grease removal devices) is amended by deleting the first sentence in said section: